

Fire Emergency Plan	
Management company	Park Hill Phase 2
Managing agents	Residential Management Group: Tel- 0345 002 4444
Effective date of plan	January 2022
In the event of Fire	Action
How people will be warned if there is a fire.	Independent smoke and heat detectors are fitted within each flat that will provide warning within the single flat only.
If a fire breaks out in your home	Verbally raise the alarm by shouting "Fire". Warn all persons within your flat and leave together. Where possible turn off your cooker or oven. Where possible close windows and doors, especially the front door. Do not attempt to put out the fire. Do not put yourself at risk. Do not use the lifts. Leave the building by the stair and available exit which is currently open (this has the fireman's access and has the dry riser and fireman's lift) and move to a safe place away from the block. Call the fire service.
If you see or hear of a fire in another part of the building	The building is designed to contain a fire in the flat where it starts. This means it will usually be safer for you to stay in your flat if the fire is elsewhere. Ensure your entrance door is fully closed. You must leave immediately if smoke or heat affects your home, or if you are told to do so by the fire service. If you are in any doubt, get out and move to a safe place away from the block. Do not use the lifts.
Hearing the alarm (relevant persons who may be elsewhere in the building or car park)	Leave the building by the nearest available exit and move to a safe place away from the block. Do not use the lifts. If you have visitors or contractors with you, instruct them to follow you.
How will the emergency services be notified and who is responsible	The person finding the fire will dial 999 or 112. When the operator answers, give your telephone number and ask for FIRE. When the fire service replies give the address where the fire is: Park Hill Phase 2, Sheffield, S25QY. Do not end the call until the fire service has repeated the address correctly.
Arrangements for the safe evacuation of people identified as being especially at risk	Details of any individuals with special needs may be kept inside a Premises Information Box (PIB) held in reception.
Plans to deal with persons once they have left the premises	All evacuated personnel should remain at a safe place approximately 50m away from the building. No individual should re-enter the building for any reason until they have been instructed to do so.